



NOTES:

- WHERE ANCHOR IS CAST PRIOR TO BASE, KEY SHALL BE FORMED AS SHOWN AND AGGREGATES ON FACE OF CONSTRUCTION JOINT SHALL BE EXPOSED. QUALITY OF ANCHOR CONCRETE SHALL BE THE SAME AS SPECIFIED FOR THE BASE SLAB.
- ANCHOR BARS AND STIRRUPS:
16mm DIA GRADE 400Y
- ANCHOR SHALL EXTEND FULLY ACROSS BASE SLAB.
- MESH REINFORCEMENT SHALL BE LOCATED IN THE TOP THIRD OF THE BASE AND SHALL HAVE A MINIMUM COVER OF 50mm UNLESS SHOWN OTHERWISE.

E				GENERAL NOTES / CROSS REFERENCES																	
D				1. EXPANSION JOINT DETAIL	SD 5401																
C	J.C.	1.7.95	GENERAL NOTES 2 & 3, GRADE OF ANCHOR BARS & STIRRUPS, SUBSURFACE DRAINS	2. SELECTION GUIDE	SD 5300																
B	M.P.	5.2.90	NOTES 1, 2 & 4 - F82 STEEL FABRIC	3. ALL DIMENSIONS ARE IN MILLIMETRES																	
A	M.P.	19.9.89	ANCHOR TAPERED THROUGH SUB BASE																		
AMEND.	Appd.	Date		AMENDMENTS																	



PRINCIPAL ROAD DESIGN ENGINEER'S DEPARTMENT

STANDARD DRAWING
CONTINUOUSLY REINFORCED CONC. PAVEMENT (CRCP)
TRANSVERSE JUNCTION OF CONCRETE AND FLEXIBLE PAVEMENTS

APPROVED <i>[Signature]</i> PRINCIPAL RD ENGINEER	DATE 1.7.95	SPEC. REF. No. 501-521	SHEET No.	DRAWING No. SD 5381	AMENDMENT C
---	----------------	---------------------------	-----------	------------------------	----------------