



SECTION A-A

NOTES:

1. PIT SIZE: 750 x 1000 (INTERNAL DIMENSIONS).
2. PIT REINFORCEMENT - F92 FABRIC. FABRIC IN SHAFT SHALL HAVE THE MAIN BARS POSITIONED HORIZONTALLY. LAPS TO BE 300 MIN. CLEAR COVER TO BE 50 MIN. CORNER RETURN REINFORCEMENT MAY BE FABRIC OR EQUIVALENT BARS. BARS GRADE 400Y & FABRICS TO COMPLY WITH AS/NZS 4671. CONCRETE SHALL BE NORMAL-CLASS N32 STANDARD STRENGTH GRADE OR HIGHER COMPLYING WITH THE REQUIREMENTS OF AS 1379. EXPOSURE CLASSIFICATIONS UP TO AND INCLUDING B1.
3. PITS DEEPER THAN 1000 SHALL BE FITTED WITH STEP IRONS. REFER SD 1041.
4. PRECAST UNITS MAY BE CONSTRUCTED TO THE MANUFACTURER'S DETAILS. THE DESIGN SHALL COMPLY WITH THE AS 5100 BRIDGE DESIGN AND THE FOLLOWING ADDITIONAL REQUIREMENTS :
  - COMBINED FACTORED LATERAL PRESSURE AT ANY POINT AT THE ULTIMATE LIMIT STATE SHALL BE NOT LESS THAN 25 kPa.
  - ADEQUATE DRAINAGE SHALL BE PROVIDED TO PIT WALLS TO AVOID HYDROSTATIC PRESSURE.
  - VERTICAL LOAD 210 kN APPLIED ANYWHERE ON PIT.
  - MINIMUM REINFORCEMENT AREA SHALL BE 150 mm<sup>2</sup>/m.
  - CONCRETE SHALL BE NORMAL-CLASS N32 STANDARD STRENGTH GRADE OR HIGHER COMPLYING WITH THE REQUIREMENTS OF AS 1379. EXPOSURE CLASSIFICATIONS UP TO AND INCLUDING B1.
5. CONCRETE FRAMES TO BE SET ON 5 mm OF MORTAR.

sd-1141c.dgn 20/03/2006 12:22:14 PM

E			
D			
C	J.K.	1/7/05	AS 1302 & 1304 SUPERSEDED BY AS/NZS 4671. AUSTRALIAN BRIDGE CODE 1996 SUPERSEDED BY AS 5100 BRIDGE CODE
B	J.C.	1/2/98	AMENDMENT TO NOTES 2 & 4, CONCRETE STRENGTH GRADES
A	J.C.	1/9/94	NOTES 2, 4 & 5, GENERAL NOTE 5, COVERS, SECTION A-A.
ISSUE	APP'D	DATE	AMENDMENT

GENERAL NOTES	
1. PIT DIMENSIONING & SETTING OUT DETAILS	SD 1001
2. UNHAUNCHED PITS	SD 1011
3. STEP IRONS	SD 1041
4. PIT COVERS	SD 1051
5. ALL DIMENSIONS ARE IN MILLIMETRES	

DESIGNED	PRINCIPAL ROAD DESIGN ENGINEER
APPROVED	16.9.94
CATALOG PROJECT	PRED sddgnnew
FILENAME	sd-1141c.dgn

SCALE OF	HOR METRES	VER
		NOT TO SCALE

STANDARD DRAWING				
END ENTRY PIT				
FILE NO.	CONTRACT NO.	SHEET NO.	DRAWING NO.	ISSUE
			SD 1141	C